



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE150304004481

Product Switch-Disconnecter

Applicant Zhejiang Benyi Electrical Co., Ltd
Zhongshi Village, Panshi, Yueqing City (Inside Yueqing tongHai
Mechanical Equipmeng Factory) Zhejiang Province

Type/model BYS-63, BYS.1-63, BYS.2-63

Technical data see the appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2014CQC0304-006949, the submitted sample of the above item complies with:

**EN 60947-3:2008(Third edition)+A1:2012 in conjunction with EN 60947-1:2007
(Fifth edition)+A1:2010**

and fulfill testing requirement of the European Directive:

2006/95/EC

President:



Date of issue: Apr.01 2015

Date of expiration: Apr.01,2018



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

BYS-63, BYS.1-63, BYS.2-63

Ui: 1500V;

Ith: 63A;

Diagram2: DC800V/25A, DC900V/20A, DC1000/1200V/16A, DC1500V/5A;

Diagram2H: DC600V/50A;

Diagram4: DC600V/32A, DC800V/23A, DC1000V/16A, DC1200V/10A, DC1500V/5A;

Diagram4S/4B: DC600/800V/32A, DC1000V/40A, DC1200V/32A, DC1500V/16A;

Diagram4T: DC600/800V/32A, DC1000V/1200V/32A, DC1500V/16A;

Diagram6: DC600/32A, DC800V/23A, DC1000V/16A, DC1200V/10A, DC1500V/5A;

Diagram3H: DC600V/63A;

Diagram6S/6B: DC600/800/1000/1200/1500/32A;

Icw: 8kA/1s;

Icm: 8kA;

DC-21B;

IP66(BYS-63)



Diagram 2




Diagram 2H




Diagram 4




Diagram 4S




Diagram 4B




Diagram 4T




Diagram 6




Diagram 3H




Diagram 6S




Diagram 6B