

Zertifikat *Certificate*



Zertifikat Nr. *Certificate No.*
R 50204846

Blatt *Page*
0002

Ihr Zeichen *Client Reference*
X.X.Z.

Unser Zeichen *Our Reference*
01-KSH- 15043932 004

Ausstellungsdatum
02.08.2016

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

ZHEJIANG GALAXY FUSE CO., LTD.
Liushi Changchun Industrial Zone,
Wenzhou, Zhejiang 325604
P.R. China

Fertigungsstätte *Manufacturing Plant*

ZHEJIANG GALAXY FUSE CO., LTD.
Liushi Changchun Industrial Zone,
Wenzhou, Zhejiang 325604
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*

EN 60269-1:2007+A1
EN 60269-6:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Fuse Link (Low-voltage Fuse for PV System)

as page 0001

Additional ratings for

Type Designation : YRPV-30

2

Rated Current : 25A and 30A

Rated Breaking Capacity : 15kA

Rated Power Dissipation : no more than 3,0W at 0,7In
no more than 6,0W at In

2

ANLAGE (Appendix): 1.1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Tel. (+49/221)8 06 - 13 71 e-mail cert-validity@de.tuv.com
Fax. (+49/221)8 06 - 39 35 http://www.tuv.com/safety



Jie Zhang